

#### **GENERAL ORDER 165**

#### UTILITY MAINTENANCE MANAGEMENT SYSTEM

**REPORT FOR** 

2023

This report presents the results of annual inspection and maintenance of electric distribution facilities of the City of Moreno Valley's Electric Utility (MVU) covering the period from January 1, 2023, to December 31, 2023.

MVU's electronic Utility Maintenance Management System (UMMS) is used to collect all data subject to GO 165. Each month, UMMS prepares a report showing the various pieces of equipment that are due for inspection or maintenance the following month based on the original equipment installation date recorded on UMMS or the date of the last inspection or maintenance of a specific piece of equipment. The report identifies the required equipment maintenance or inspections by structure or equipment number and is also documented in MVU's Geographic Information System (GIS) maps. A handheld Mobile Data Terminal (MDT) is used by field personnel to record all inspections and maintenance of each item of equipment. The data from the MDT is up-loaded daily to the UMMS. The maintenance history is archived for each piece of equipment in UMMS. A monthly report is generated from UMMS that identifies any equipment that may be overdue for inspection or maintenance for immediate follow-up.

#### Summary

MVU's objective during General Order 165 inspections is to effectively plan, report on, and sustain the maintenance of electrical grid equipment, aligning in accordance with General Order guidelines and timelines.

## **GENERAL ORDER 165**

## 2023

# MAINTENANCE

### REPORT

					Types of Inspections				
Main Category	Type of Equipment/ Structure	Total Structures in 2023	Scheduled for Inspection in 2023	Percent Scheduled for Inspection in 2023	Patrol	Detail	Mainten- ance	Total inspected in 2023	Percentage Scheduled and Inspected in 2023
Below Ground Equipment									
	Gas Switch	26	26	100.00%	0	26	0	26	100.00%
	Burd Transformer	2	2	100.00%	1	1	0	2	100.00%
Surface Mounted Equipment									
	Capacitors	26	25	96.15%	18	8	0	26	104.00%
	Fuse Cabinets	8	8	100.00%	6	2	0	8	100.00%
	Interconnect	3	3	100.00%	3	0	0	3	100.00%
	Switch	161	156	96.89%	126	30	3	156	100.00%
	Transformer	867	830	95.73%	520	310	13	830	100.00%
	Pad Mounted Junction	1	1	100.00%	1	0	0	1	100.00%
Vaults and Substructure Enclosures									
	Structures (MH, PB/SB, V)	434	108	24.88%	75	33	0	108	100.00%
Street Lighting									
	Street Light - LS-1	2389	2316	96.94%	2374	0	46	2374	102.50%
	Street Light - LS-2	9495	9495	100.00%	9495	0	150	9495	100.00%

#### **MVU CMP INSPECTION CYCLES**

	PATROL*	DETAILED**		
	Urban	Urban		
Below Ground Equipment				
Blowers and Thermostat	N/A	N/A		
Fuse Cabinets	Annual	YEAR 3		
Transformers	Annual	YEAR 3		
Gas Switches	Annual	YEAR 3		
Surface Mounted Equipment				
Pad Mounted Capacitors	Annual	YEAR 5		
Pad Mounted Transformers	Annual	YEAR 5		
Pad Mount Fuse/ Switch	Annual	YEAR 5		
Vaults and Substructure Enclosures***				
Structures	With Equipment			
Cable	With Equipment			
Terminations	With Equipment			
Splices	With Equipment			
Street Lighting	Annual			

### MVU Inspection Cycles (Maximum Intervals in Years)

\*<u>Patrol</u> is defined as a simple visual inspection that is designed to identify obvious problems and hazards as well as GO 95 and GO 128 infractions.

\*\*<u>Detailed inspection</u> is defined as one where individual pieces of equipment and structures are carefully opened and examined.

\*\*\*<u>Vaults and Substructure Enclosures without Equipment (Splices only)</u> – Self-imposed, not required per General Order 165.

NOTE: MVU has no overhead facilities.